

**INSTALLATION
INSTRUCTIONS**

FIXTURE TYPE _____

P-ID-9700
BAFFLE

PART
NO. 510349-1000

PG. 1
OF 1


DO NOT MODIFY OR ALTER THIS PRODUCT IN ANY WAY, OR INSTALL IN ANY FASHION WHICH IS CONTRARY TO THE INSTRUCTIONS CONTAINED HEREIN.
IF YOU HAVE ANY QUESTIONS REGARDING THIS PRODUCT OR THE INSTALLATION OF IT, PLEASE CALL LITECONTROL ENGINEERING AT 617-294-0100.

GENERAL NOTES:

- A) BAFFLES ARE THE LAST ITEMS INSTALLED ON THE JOB. LAMPS (BY OTHERS) MUST BE INSERTED INTO SOCKETS PRIOR TO BAFFLE INSTALLATION.
- B. ALL BAFFLES ARE SHIPPED IN 4' LENGTHS.

INSTRUCTIONS: (USE CAUTION WHEN INSTALLING BAFFLES TO PREVENT LAMP DAMAGE.)

1. STARTING AT ONE END OF ROW ATTACH STEEL WIRE BAFFLE RETAINERS TO HOLES IN BAFFLE. ALL BAFFLES ARE INSTALLED BY LIFTING AND SHIFTING THEM THRU THE FIXTURE OPENING AND LOWERING INTO PLACE. BAFFLES SIT ON TOP OF BOTTOM RAILS. (SEE CROSS SECTION BELOW)



CROSS SECTION

LITECONTROL

100 HAWKS AVENUE - PO BOX 100 - HANSON MA 02341, (617-294-0100)